



State Fire Marshal's Office

PO Box 12107 | Austin, TX 78711 | 512-676-6800 | tdi.texas.gov/fire

4/17/2023

Chief Jacob Slott
PO Box 975
New Waverly, TX 77358

Place code: 47181
Community: Walker City ESD No 02

Dear Chief Jacob Slott:

Insurance Services Office (ISO) has submitted a recommendation concerning your community's Public Protection Classification (PPC). Currently, the community's Public Protection Classification is a Class Unclassified.

Insurance Services Office is recommending the Public Protection Classification be updated as a split Class 03/3Y, with an effective date of 9/1/2023. The recommendation is based on a review of your community performed on 1/9/2023.

With a split class, all class-rated properties located within 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 03. All class-rated properties located farther than 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 3Y.

Public Protection Classifications range from 1 (superior) to 10 (does not meet minimum criteria).

We have reviewed the information provided and believe it is enough to grant approval. The Insurance Services Office will be notified of our approval of their recommendation and the effective date.

Please make sure all community officials and residents within your district are notified of the new Public Protection Classification rating for your community, and the effective date.

Please share your experience with your Public Protection Classification grading by taking a brief survey at the following link.

[Public Protection Classification Service Feedback Survey \(surveymonkey.com\)](https://www.surveymonkey.com)

Thank you,



Joel Duke
PPC Oversight Officer
PPCOversight@tdi.texas.gov

TEXAS STATE FIRE MARSHAL

Approved

Disapproved

Signature:  Date: 05-01-2023